



November 30, 2010

JOSAM
CARL PARKER
2501 S. FRONT STREET
PHILADELPHIA PA 19148

CHIBRO S.P.A.
MORENO TERZAGHI
VIA VALTELLINA 15
+39 031 47 81 800 +39 031 54 14 11
ITALY

Re: Description: PIPES AND FITTINGS, STAINLESS STEEL
Manufacturer: CHIBRO S.P.A.
Product Name: JOSAM PUSH-FIT STAINLESS STEEL PIPE & FITTINGS
Model Number(s): 1 1/2" THROUGH 8"
FITTING LIST IN ATTACHMENT A
Product File No: 20100417

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Effluent piping gravity flow non-perforated
 - b. Effluent piping gravity flow perforated
 - c. Sanitary drain and vent piping. . gravity flow aboveground
 - d. Sanitary drain and vent piping. . gravity flow underground
 - e. Sanitary sewer gravity flow
 - f. Storm drain and vent piping . . . gravity flow aboveground
 - g. Storm drain and vent piping . . . gravity flow underground
 - h. Storm sewer gravity flow
 - i. Subsoil drain piping gravity flow

- The pipe and fittings shall be labeled with the manufacturer's name or trademark, nominal pipe size, date of manufacture. Type of alloy pipe, Type 304 and Type 316L shall be marked along the continuous length of pipe. **Type 304 shall be marked to read "above ground only."**

- Installation of this product must be in accordance with ASME Standard A112.3.1-2007.

JOSAM
Page 2
November 30, 2010

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov