



October 12, 2010

GREATENS SEPTIC SERVICE, INC.
GALE GREATENS
3483 KEWAUNEE RD.
GREEN BAY WI 54311

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: GREATENS SEPTIC SERVICE, INC.
Product Name: **SEPTIC, HOLDING OR PUMP* (was 20060225)**
Model Number(s): 1250
(43.5 IN. L.L., 29.18 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 1276.75 GAL. ACTUAL CAPACITY; 608 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; **TANK DIMENSIONS = 115 IN. L X 62 IN. W X 43.5 IN. H)**
Product File No: 20100419

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- The products produced by this manufacturer are approved to use the following:
 - One-inch schedule 40 PVC cast in riser for electrical wiring.
 - Bottom openings for holding tank and for pump tank or compartment.
 - Department approved effluent filter designed installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Access opening cover with 4-inch opening.
 - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
 - Department approved plastic risers and covers.
- **Bedding: tank shall be placed with a min. of 3 in. sand pad or gravel.**
- When used as septic or pump tank, Best GF 10-8 filter or equivalent may be installed.

GREATENS SEPTIC SERVICE, INC.
Page 2
October 12, 2010
PRODUCT FILE NO. 20100419

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

*** his letter is to inform you that on MARCH 1, 2009 revised chapters COMM 82 and 84 of the Wisconsin Administrative Code went into effect. The revisions include the deletion of the requirement for plumbing product approval for EXTERIOR GREASE INTERCEPTORS, s. Comm 84.10. REVIEW OF EXTERIOR GREASE INCEPTORS WILL BE CONDUCTED AT THE TIME OF PROJECT-SPECIFIC PLAN REVIEW.**

This approval supersedes the approval issued on 6/13/2006 under product file number 20060225.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060225.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV