



December 6, 2010

SIM / TECH FILTER
KOTESKEY BROTHERS EXCAVATING INC.
GARY KOTESKEY
06598 HORTON BAY N RD.
BOYNE CITY MI 49712

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: SIM / TECH FILTER
Product Name: GAG SIM/TECH FILTER
Model Number(s): STF-100, STF-100A, STF-100A2 AND STF-100A3
[>1/16 IN. FILTRATION; INSTALL SINGLY OR IN MULTIPLES]
Product File No: 20100474

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of FEBRUARY 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- The sizing calculations of the pressure distribution network must include 0.5 feet head loss for this product.
- Installation recommends minimum 2-in. diameter frost protected force main; sch. 80 union, and adequate access for installation and maintenance. Device has permanently affixed label: Gag SIM/TECH Filter.
- Additional information is included as attachment(s) to this letter; see attachment A and B.

This approval supersedes the approval issued on 9/10/2009 under product file number 20060020. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060020.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV