



January 24, 2011

ARLYN STENCIL  
R5442 CTY RD. H  
EDGAR WI 54426

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED  
Manufacturer: ARLYN STENCIL  
Product Name: HOLDING TANKS  
Model Number(s): A-4211 (4211 gal. capacity)  
(80 IN. L.L., 52.64 GAL/IN., 120 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS = 152  
IN. X 80 IN. W X 80 IN. H)  
B-4876 (4876 gal. capacity)  
(80 IN. L.L., 60.95 GAL/IN., 120 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS = 176  
IN. X 80 IN. W X 80 IN. H)  
C-6206 (6206 gal. capacity)  
(80 IN. L.L., 77.53 GAL/IN., 120 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS = 224  
IN. X 80 IN. W X 80 IN. H)  
Product File No: 20100488

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of January 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- This product must be installed with a Spartan Chemical Co., Inc. model 9111 Vent T Connector fitting permanently connected to the inlet of the hose serving this product when the product is not served by a separate water supply connection.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- **BEDDING AND BACKFILL: A 6-inch layer of 1 ½ inch rock placed under tank to level and fill-in voids. Use dry backfill material; if material is not dry substitute sand fill with some stone, 3 in. or less in size. Compact backfill every 12-15 inches until the tank is covered.**

This approval supersedes the approval issued on 1/6/2006 under product file number 20050916. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050916.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV