



January 19, 2011

AMERICAN MANUFACTURING COMPANY
ROBERT B. MAYER, P.E.
PO BOX 97
ELKWOOD VA 22718-0549

NETAFIM USA
ZVI E. STELLA, PRESIDENT/CEO
5470 E HOME AVE.
FRESNO CA 93727

Re: Description: PIPES, POLYETHYLENE
Manufacturer: NETAFIM USA
Product Name: BIOLINE DRIPER LINE, NETAFIM PRESSURE COMPENSATING EMITTER
Model Number(s): BIOLINE DRIPPER LINE .4, BIOLINE DRIPPER LINE .6, BIOLINE DRIPPER LINE .9
Product File No: 20110011

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30(2)(d)3. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product may only be installed for the following drain or vent use(s):
 - a. Effluent piping pressurized non-perforated
 - b. Effluent pipingpressurized perforated
- This product must receive influent that has a maximum particle size of 1/8 inch.

This approval supersedes the approval issued on February 21, 2001 under product file number 20010075.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010075.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov