

March 28, 2011

LEDGEVIEW PRECAST CONCRETE, INC.
ALLEN E. FREUND
N6672 COUNTY TRUNK UU
FOND DU LAC WI 54937

Re: Description: **SEWAGE TREATMENT APPARATUS & TANK SYSTEM [SEE STA -SEWAGE TREATMENT APPARATUS] ***
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.
Product Name: TRASH/0.75, TRASH/0.5 TRASH/0.9, TRASH/1.0 MICRO-FAST; AND TRASH/1.5 HIGH STRENGTH FAST
Model Number(s): **800/1200 BIO-MICROBICS**
[50 L.L.; 48 IN. MAX. DEPTH OF BUR.; SEE SEPARATE APPROVAL FOR PERFORMANCE OF TREATMENT APPARATUS]
Product File No: 20110043

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- Also refer to the Commerce product approval stipulations for the sewage treatment apparatus, which may include: maximum daily wastewater flow, influent strength, maximum BOD5, and maintenance intervals.
- **To determine treatment credits for residential and commercial POWTS designs, see stipulations regarding max. BOD5, DWF, approved effluent filters, etc. contained in approval letters for the specific treatment device; see <http://commerce.wi.gov/SB/SB-ProductsEvalProgram.html#Plum> .**
- **Tank bedding and burial depth: A minimum of 4 in. of ¾ in. clear stone overlying a firm uniform base. Bedding should be level around the perimeter and concave at the middle. For tank burial depths greater than 48 in., contact manufacturer for alternate installation instructions.**

LEDGEVIEW PRECAST CONCRETE, INC.

Page 2

March 28, 2011

Product File No: 20110043

- **BACKFILL: Backfill material must be placed in uniform mechanically compacted layers of less than 24 in. thick. Fill must be placed nearly equally around the tank. Materials must be free of stones (>3 in. dia.) or other debris; each layer being adequately compacted. To prevent flotation during backfill, fill the tank 1/3 full with water or keep water pumped out of the excavation until backfilling is complete.**

This approval supersedes the approval issued on INSERT DATE 3/28/2006 under product file number 20060901.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060901.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

*** SEE ON-LINE APPROVALS FOR SEWAGE TREATMENT APPARATUS/TANK SYSTEMS AT:**

[http://commerce.wi.gov/php/sb-ppalopp/prodcode_result.php/STATS/SEWAGE TREATMENT APPARATUS & TANK SYSTEM \[SEE STA - SEWAGE TREATMENT APPARATUS](http://commerce.wi.gov/php/sb-ppalopp/prodcode_result.php/STATS/SEWAGE_TREATMENT_APPARATUS_&_TANK_SYSTEM)

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV