



May 18, 2011

LUBRIZOL
JOHN PRITCHARD
9911 BRECKSVILLE ROAD
BRECKSVILLE OH 44141

Re: Description: PIPES AND FITTINGS, CPVC
Manufacturer: LUBRIZOL
Product Name: **CORZAN HP**
Model Number(s): **SCH 80 IPS CPVC PIPE AND FITTINGS UP TO 4"**
Product File No: 20110054

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product is approved through the testing and certification of NSF SE 8459. This Special Engineered Specification (SE) tests Schedule 40 and 80 pipe and fittings high HDB at 180 degrees.

An NSF SE Specification is similar to a consensus standard, such as an ASTM standard in that it defines the physical properties and performance characteristics of a product. SE Specifications are developed by NSF international and other interested parties to evaluate new and innovative products when on consensus standard exists.

This product meets or exceeds the adopted standards of the Wisconsin Uniform Plumbing Code. Also meets the required temperature and pressure requirements in Comm 84.30 (4) (e).

- This product shall only be used with fittings made by **HARVEL, NIBCO AND IPEX.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov