

April 18, 2011

LAKE SHORE BURIAL VAULT CO., INC.  
HUBERT MCQUESTION  
12780 LISBON ROAD  
BROOKFIELD WI 53005

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.  
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, HOLDING, OR PUMP  
Model Number(s): 3350/1650 (5000 GAL. 2-COMPARTMENT)

(61 IN. L.L., 54.92/27.05 GAL/IN., 96 IN. MAX. DEPTH OF BURY, 2394 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK OR 1604 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; **TANK DIMENSIONS = 220.3 IN. L X 80.13 IN. W X 61 IN. H)**

**Product File No: 20110120**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of April 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- When the optional side inlets and/or outlets located along the side of the tank within 21 inches of the outside corner of the tank are used in this product as a septic tank, the inlet and outlet may not be located at the same end of the tank.
- **BEDDING: For tanks under 2,000 gal. capacity, a minimum of 3 inches of sand or stone must be used. When sand is used, excavation must be made to prevent sand from washing out under the tank. Stones the size of #2 and under are acceptable.**

LAKE SHORE BURIAL VAULT CO., INC.

Page 2

April 18, 2011

**Product File No: 20110120**

- **BACKFILL: When cover is greater than 48 in., backfill around tank with material described in BEDDING stipulation.**
- An optional 8 in. diameter inlet may be located at the end of tank or through the tank cover. When located at end wall, location shall be below manhole opening. When located through cover, location shall be no greater than 20 inches from sidewall.

This approval supersedes the approval issued on 6/8/2009 under product file number 20090206.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20090206.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@WI.GOV