

May 18, 2011

XERXES CORPORATION
MIKE SLOAN
7901 XERXES AVE SOUTH
MINNEAPOLIS MN 55431

Re: Description: SEWAGE TANKS, FIBERGLASS
Manufacturer: XERXES CORPORATION
Product Name: HOLDING
Model Number(s): 8' DIA. 8000 GAL. (ACTUAL CAPACITY 7708 GALS.)

[84 IN. L.L; FOR DEPTH OF BURY SEE ATTACHMENT; FOR GALS./IN. SEE
ATTACHMENT; TANK DIMENSIONS = 26 FT. 0.5 IN. L X 8 FT. DIA.)

Product File No: 20110157

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, the plan approval and s. Comm 83.15 (4), Wis. Admin. Code. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval and code requirements will take precedence.
- The side openings and lower end opening on this product may only be used when this product is installed as a holding tank.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- The manhole cover shall be provided with a locking device that conforms to s. Comm 84.25 (7)(h) of the Wisconsin Administrative Code.

- **OPTIONAL 30 IN. DIA RISERS:** XERXES PVC access risers in one-inch increments starting in 2- and 6-ft. with gasketed covers and self-tapping screws. Joints between riser sections shall be sealed with gasket and adhesive supplied by the manufacturer and the riser must be installed on existing tanks in accordance with the riser manufacturer's installation instructions. Access riser includes hinged and lockable cover and warning label. Tank alarm installed via approved 4 in. dia. PVC vertical pipe through access cover.
- **Additional information is included as attachment(s) to this letter; see attachment A and B.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV