



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Paul F. Jadin, Secretary

May 13, 2011

GREEN4ALL ENERGY SOLUTIONS INC.
DAN HANDLEY
PO BOX 3961
ST.CHARLES IL 60174

NEVES-INC.
MICHEL FALIGANT
PO BOX 1243
ANGUILLA
BRITISH WEST INDIES

Re: Description: ALTERNATE PRODUCT REVIEW
Manufacturer: NEVES-INC.
Product Name: H2 MINUS 0
Model Number(s): H2-3/4", 1", 1 1/2", 2", 3", 4", 6", 8", 10" AND 12"
Product File No: 20110167

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The Water Supply (water fittings) regulations 1999 are designed for the prevention of waste, undue consumption, misuse or contamination of the drinking water. The Water Regulations Advisory Scheme (WRAS) specifies test to determine whether products used on consumer premises conform to the Regulations. For non-metallic products the WRAS uses the methods and criteria in BS6920:2000. This product conforms to the BS6920: 2000 listing.

It has been determined by this office that the BS6920: 2000 listing is equivalent to NSF 61. (Drinking Water System Components Health Effects) **This approval is for material quality only.** It is not an approval for performance.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov