



May 25, 2011

NORWESCO, INC.
ANASTASIA R. O'HARA
PO BOX 439
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: NORWESCO, INC.
Product Name: SEPTIC, PUMP OR HOLDING; SEPTIC/SEPTIC
Model Number(s): 1250 BSR
(52.25 IN. L.L., 36 IN. MAX. DEPTH OF BURY, 625 G.P.D. WHEN USED AS A SEPTIC
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER;
TANK DIMENSIONS = 116 IN. L X 55 IN. W X 66 IN. L)
Product File No: 20110175

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of AUGUST 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- This tank must be filled up to 13 inches from bottom of tank after installation or when pumped empty and the lowest liquid level of the tank when used as a pump or holding tank must be 13 inches.
- When the optional divider wall is installed and the tank is used as a double compartment septic tank (ST) /ST, there shall be a separator wall with 4 5/8-inch hole through to the second compartment. The second compartment shall allow the installation of an effluent filter. This option is not for use as a ST/PC (pump chamber).

This approval supersedes the approval issued on 5/07/2004 under product file number 20070189.

NORWESCO, INC.
Page 2
May 25, 2011
PRODUCT FILE NO. 20110175

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070189.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV