

June 10, 2011

GREATENS SEPTIC SERVICE, INC.
GALE GREATENS
3483 KEWAUNEE RD.
GREEN BAY WI 54311

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: GREATENS SEPTIC SERVICE, INC.
Product Name: SEPTIC OR PUMP
Model Number(s): 758
(36 IN. L.L., 21.3 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 367 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS = 82 IN. L X 60 IN. W X 36 IN. H)
Product File No: 20110185

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2016.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- The products produced by this manufacturer are approved to use the following:
 - One-inch schedule 40 PVC cast in riser for electrical wiring.
 - Bottom openings for holding tank and for pump tank or compartment.
 - Department approved effluent filter designed installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Access opening cover with 4-inch opening.
 - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
 - Department approved plastic risers and covers.
- Bedding: tank shall be placed with a min. of 3 in. sand pad or gravel.
- When used as septic or pump tank, Best GF 10-8 filter or equivalent may be installed.

GREATENS SEPTIC SERVICE, INC.

Page 2

June 10, 2011

This approval supersedes the approval issued on INSERT DATE under product file number #####.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #####.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV