



July 6, 2011

KLENZOID, INC.  
 DIOX(R) WATER HYGIENE  
 JOE HANNIGAN  
 912 SPRING MILL AVE  
 PO BOX 389  
 CONSHOHOCKEN PA 19428

POWERSEAL PIPELINE PRODUCTS CORP.  
 CULLEN ALLRED  
 701 PLEASANT VIEW DR  
 WICHITA FALLS TX 76306

Re: Description: PIPE SADDLES-WATER  
 Manufacturer: POWERSEAL PIPELINE PRODUCTS CORP.  
 Product Name: TAPPED SADDLE CLAMPS  
 Model Number(s): 3131 AS  
 Product File No: 20110210

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5)(d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Size of the NPT tapped outlet must in accordance the below Table 1 entitled Minimum Outside Dimension of Pipe and Clamp Length for given NPT Tapped Outlet Size.

Table 1  
 Minimum Outside Dimension of Pipe and Clamp Length for given NPT Tapped Outlet Size

Outlet Size in inches	Minimum pipe OD in inches	Minimum Clamp Length in inches
3/4	2.38	6
1	2.38	6
1-1/4	2.88	8
1-1/2	3.50	8
2	3.50	8
3	6.63	12

POWERSEAL PIPELINE PRODUCTS CORP.

Page 2

July 6, 2011

20110210

This approval supersedes the approval issued on December 7, 2006 under product file number 20060519.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060519.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: [jerry.thompson@wi.gov](mailto:jerry.thompson@wi.gov)