



August 2, 2011

QUANICS, INC.
BRIAN BORDERS
PO BOX 1520
CRESTWOOD KY 40014

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS
Manufacturer: QUANICS, INC.
Product Name: ZEUS ACCESS SYSTEM RISERS AND LIDS
Model Number(s): RISERS: 22 INCH: RB-L-22; RB-RTA-22x2; RB-CTA-22x6; RB-R-22x6; RB-R-22x12 and RB-R-22x38;
26 INCH: RB-L-26; RB-RTA-26x2; RB-CTA-26x6; RB-R-26x6; RB-R-26x12 and RB-R-26x38
TANK ADAPTER: RB-PTA-26x2
[CAST-IN OR RETROFIT HDPE RISERS IN MULTIPLE HEIGHTS AND NEOPRENE GASKETS]
Product File No: 20110233

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of OCTOBER 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- The manhole cover must be secured to the riser using screws which are not standard or phillips head to be considered an effective locking device.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- Joints between riser sections shall be sealed with neoprene gasket supplied by the manufacturer and the riser must be installed on state-approved tanks in accordance with the riser manufacturer's installation instructions.
- **For high groundwater installations, refer to manufacturer's installation recommendations.**

This approval supersedes the approval issued on 7/24/2008 under product file number 20060182.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060182.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV