



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**  
**Scott Walker, Governor**  
**Dave Ross, Secretary**

August 18, 2011

DSPS  
SAFETY AND BUILDINGS  
JIM MILLER  
201 W WASHINGTON AVE  
MADISON WI 53701

Re: Description: FAUCET, ENVIRONMENTAL SUICIDE PREVENTION  
Manufacturer: DSPS  
Product Name: SPOUT & ACTION COMBINATION for PSYCHIATRIC CARE FACILITIES  
Model Number(s): NONE  
Product File No: 20110262

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.50(2)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Neither the spout nor action creates a cross connection situation.
- This alternate spout and action combination is only permitted to vary from s. Comm 82.50 (2) (b) when utilized within psychiatric care facilities where patient safety is at risk when standard goose neck spouts and actions are installed.
- The faucet spouts and actions must comply with the Department of Health and Family Service's standards for environmental suicide prevention.

This approval supersedes the approval issued on July 5, 2006 under product file number 20060306.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060306.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

James H. Miller  
Section Chief, Bureau of Integrated Services  
Phone: 608-266-8072  
Fax: 608-267-9566  
email: jim.miller@wi.gov