



September 7, 2011

HYDRO-ACTION
SALES MANAGER
2055 PIDCO DR
PO BOX 640
PLYMOUTH IN 46563

Re: Description: SEWAGE TANKS, FIBERGLASS
Manufacturer: HYDRO-ACTION
Product Name: PUMP
Model Number(s): 750 GALLON
63.0 IN L.L.; (12.83 GAL/IN, 18 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS = 59.88
IN. DIA. X 63 IN. H)
Product File No: 20110265

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2016.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product must be installed downstream of a treatment tank which provides a minimum 24 hour retention of the average daily design flow.
- The manhole cover shall be provided with a locking device that conforms to s. Comm 84.25 (7)(h) of the Wisconsin Administrative Code.
- **Bedding: Tanks must be placed on suitable soils capable of bearing the weight of tank and contents when full. Soft soils or bedrock must have 6 inches of tamped material, sand or pea gravel.**
- **Backfill: Fill must be free flowing soil or gravel of no larger than ¾ inch. Fill tanks with water while backfilling. Compact soil in 2-foot increments until backfill is at grade.**
- Additional information is included as attachment(s) to this letter; see attachment A and B.

This approval supersedes the approval issued on 4/22/2005 under product file number 20050172.

HYDRO-ACTION

Page 2

September 7, 2011

Product File No: 20110265

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050172.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV