



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

September 26, 2011

DIVERSIFIED PRODUCTS AND RESEARCH
JEFF THOMAS
13591 CABLE ROAD SW
PATASKALA OH 43062-8812

Re: Description: SOLVENT CEMENT
Manufacturer: DIVERSIFIED PRODUCTS AND RESEARCH
Product Name: PLUMBEST SPRAY WELD
Model Number(s): S30-800, S30-801, S30-802 & S30-803
Product File No: 20110289

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.40 (14) (b) 1. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be used on PVC gravity flow DWV pipe without primer.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov