



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

September 20, 2011

ACORN ENGINEERING COMPANY
FARHAD SHAHRIARY
15125 PROCTOR AVE
CITY OF INDUSTRY CA 91746

Re: Description: FAUCET, LAVATORY
Manufacturer: ACORN ENGINEERING COMPANY
Product Name: MANIFOLDED AIR CONTROL VALVE ASSEMBLY
Model Number(s): -03-MA2, -03-MA3, -03-MA4, -04-MA2, -04-MA3 AND -04,MA4
Product File No: 20110293

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.40 (4)(c)1.b. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product because the design of the product meets the intent of s. Comm 82.40 (4)(c)1.b., Wis. Adm. Code that requires a control valve in fixture supply to each plumbing fixture. The intent of the code is met since this product provides an acceptable method of valving up to four lavatory faucets in a penal setting.

This approval supersedes the approval issued on November 13, 2006 under product file number 20060434.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060434.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov