



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

October 3, 2011

BRADLEY CORPORATION  
THOMAS R EBERHARDY  
W142 N9101 FOUNTAIN BLVD  
PO BOX 309  
MENONMONEE FALLS WI 53052-0309

Re: Description: SINKS  
Manufacturer: BRADLEY CORPORATION  
Product Name: FREQUENCY LAVATORY SYSTEMS  
Model Number(s): FL-1H, FL-1L, FL-2H, FL-2L, FL-3H, FL-3L  
Product File No: 20110297

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.32 (3)(a)2.b. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The unit must be installed in accordance with the manufacturer's instructions.
- The unit shall be installed with a Bradley Aerada 1200 series CS Faucet or equal with a thermostatic mixing valve that conforms to ASSE 1070.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov