



October 17, 2011

BIO-MICROBICS, INC.
ALLISON BLODIG
8450 COLE PKWY.
SHAWNEE KS 66227

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: BIO-MICROBICS, INC.
Product Name: SANITEE
Model Number(s): SNT 416, SNT 418
[4 IN. DIA., FLOW RANGE UP TO 1000 GPD AND 2000 GPD, RESPECTIVELY;
SCREENS PARTICLES UP TO 1/16 IN. AND 1/8 IN., RESPECTIVELY]
Product File No: 20110312

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MARCH 2017.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product must be installed in sewage treatment tanks approved by the Department of Commerce, Division of Safety and Buildings for use with this product.
- A means of venting the gases formed inside of the tank in which this product is installed shall be provided in accordance with s. Comm 84.25 (5), of the Wisconsin Administrative Code.
- This product must be installed in accordance with the manufacturer's installation instructions and with the bottom of the product above the scum level in the tank.
- This product shall be cleaned and maintained at the same time as the tank pumping interval.

This approval supersedes the approval issued on 3/6/2007 & 7/20/1010 under product file number 20070074. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070074.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV
SBD-10564-E (N.10/97)