



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

December 2, 2011

DEPARTMENT OF COMMERCE
SAFETY AND BUILDINGS
MICHAEL BECKWITH
201 W WASHINGTON AVE 4 FL
PO BOX 7162
MADISON WI 53707-7162

Re: Description: CHEMICAL DISPENSING SYSTEM, ALTERNATE FORM OF BACKFLOW PROTECTION
Manufacturer: DEPARTMENT OF COMMERCE
Product Name: CHEMICAL DISPENSING SYSTEM PROTECTION DEVICE
Model Number(s): NONE
Product File No: 20110359

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3)(a) and 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Chemical dispensing systems that are not in compliant with ASSE Standard 1055, may be installed when the installation includes an acceptable cross connection method or assembly in accordance with Comm 82.41 (3) Table 82.41-1 of the Wisconsin Administrative Code.
- The installation of the cross connection method or assembly must comply with s. Comm 82.41 (5) of the Wisconsin Administrative Code.

This approval supersedes the approval issued on May 25, 2007 under product file number 20070254.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070254.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov