



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

December 7, 2011

DSPS
SAFETY AND BUILDINGS
JIM MILLER
201 W WASHINGTON AVE
MADISON WI 53701

Re: Description: ALTERNATE SYSTEM
Manufacturer: DSPS
Product Name: ALTERNATE CHLORINATION METHOD
Model Number(s): ALTERNATE CHLORINATION METHOD FOR HOSPITAL, COMMUNITY-BASED RESIDENTIAL FACILITY, INPATIENT HOSPICE AND NURSING HOME WATER SUPPLY SYSTEMS
Product File No: 20110370

This alternative system has been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.50 (3) (b) 6. b. Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2016.

- This approval permits a minimum of 0.5 mg/l up to a maximum of 4.0 mg/l of free chlorine residual to be used for routine disinfection in the water supply of hospitals, community-based residential facilities, inpatient hospices and nursing homes.
- A CT (i.e. **C**oncentration x **T**ime) value must be constantly maintained in the context of disinfection.
- All aspects of disinfection with free chlorine as described in Chapter NR 809 of the Wisconsin Administrative Code must be adhered to.

The department is in no way endorsing this alternative system, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Safety and Professional Services
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
glen.schlueter@wi.gov **Email**
8:00AM – 4:30PM CT **Work Hours**
GWS:gws