



December 27, 2011

CASH ACME
WILLIAM CHAPIN
2400 7TH AVE SW
CULLMAN AL 35055

Re: Description: FITTINGS, COPPER, CPVC OR PEX
Manufacturer: CASH ACME
Product Name: SHARKBITE PUSH-FIT FITTING
Model Number(s): STRAIGHT COUPLING: U008, 1/2x1/2; U016, 3/4x3/4; U020, 1x1; STRAIGHT COUPLING REDUCING: U058, 3/4x1/2; U060, 1x3/4; STRAIGHT CONNECTOR: U072, 1/2x1/2 F NPT; U120, 1/2x1/2 M NPT; U068, 1/2x3/4 F NPT; U088, 3/4x3/4 F NPT; U134, 3/4x3/4 M NPT, U094, 1x1 F NPT; U140, 1x1 M NPT; U142, 1x3/4 M NPT; ELBOW: U248, 1/2x1/2; U308, 1/2x1/2 F NPT; U280, 1/2x1/2 M NPT; U334, G1/2x1/2; U350, G1/2Bx1/2; U352 G1/2Bx1/2 (ext 100); U256, 3/4x3/4; U274, 3/4x1/2; U260, 1x1; DROP EAR ELBOW: 1/2x1/2; HI-EAR ELBOW: 1/2x1/2; TEE: U362, 1/2x1/2x1/2; U370, 3/4x3/4x3/4; U412, 3/4x3/4x1/2; U444, 3/4x1/2x3/4; U454, 3/4x1/2x1/2; U374, 1x1x1; U412, 1x1x3/4; STOP END: U514, 1/2; U518, 3/4, U520, 1; PLUG: U755, 1/2; U756, 3/4; U757, 1; ADAPTER STRAIGHT: U760, 1/2 TAIL x 1/2 F NPT; U764, 3/4 TAIL x 1/2 F NPT; U766, 3/4 TAIL x 3/4 F NPT; U750, 1 TAIL x 3/4 M NPT; U752, 1 TAIL x 1 M NPT; REDUCER ADAPTOR STRAIGHT: U740, 1/2 TAIL x 1/2 M NPT; U720, 3/4 TAIL x 1/2 CARTRIDGE; U744, 3/4 TAIL x 1/2 M NPT; U746, 1 TAIL x 3/4 M NPT; U722, 1 TAIL x 1/2mm CARTRIDGE; U724, 1 TAIL x 3/4mm CARTRIDGE; CHECK VALVE: U2008, 1/2x1/2; U2016, 3/4x3/4.
U3088FLEX12, (3/4" push-fit x 3/4" NPSM -12) U3088FLEX15, (3/4" push-fit x 3/4" NPSM-15)
U3088FLEX18, (3/4" push-fit x 3/4" NPSM -18) U3088FLEX24, (3/4" push-fit x 3/4" NPSM-24)
Product File No: 20110383

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 84.40 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The fittings must be labeled with the manufacturer's name or trade mark, size and tubing material for which the fitting is intended to connect together.
- This product may be used to join together copper that complies with ASTM B88, CPVC that complies with ASTM D2846 or CSA B137.6 and PEX that complies with ASTM F876, ASTM F877 or ASTM F1281.

CASH ACME
Page 2
December 27, 2011
20110380

This approval supersedes the approval issued on May 20, 2009 under product file number 20050922.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050922.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov