



January 5, 2012

RECKITT BENCKISER INCORPORATED
HAL AMBUTER
399 INTERPACE PKWY
PARSIPPANY NJ 07054-0225

Re: Description: SEPTIC TANK ADDITIVE - CHEMICAL OR BIOCHEMICAL
Manufacturer: RECKITT BENCKISER INCORPORATED
Product Name: RID-X SEPTIC SYSTEM TREATMENT
Model Number(s): NONE
Product File No: 20120012

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2017.

This approval supersedes the approval issued on May 23, 2007 under product file number 20070182.

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.
- Based on information supplied by the manufacturer and reviewed by this department, the approval for this product recognizes this septic tank additive will not adversely affect the user, the bacterial action in septic systems, the soil hydraulic conductivity in soil absorption areas, or groundwater quality, when used in accordance with the manufacturer's instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Safety and Professional services
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
glen.schlueter@wi.gov **Email**
7:30AM – 4:30PM CT **Work Hours**
GWS:gws