



January 31, 2012

DALMARAY CONCRETE PRODUCTS, INC  
AARON AUSEN  
405 S ARCH ST  
JANESVILLE WI 53548

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: DALMARAY CONCRETE PRODUCTS, INC  
Product Name: HOLDING  
Model Number(s): 3950  
(44.0 IN. L.L., 89.8 GAL/IN., 108 IN. MAX. DEPTH OF BURY, TANK DIMENSIONS: 192 IN.  
L X 108 IN. W X 44 IN H)

**Product File No: 20120052**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of FEBRUARY 2017.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Four-inch opening located in interior wall and between a distance of 9-inches below liquid level and above 1/3 of liquid level above bottom of tank for septic tanks only.
  - Four or eight-inch opening in tank or access cover.
  - Six-inch inlet and outlet openings.
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Dual 4" four inch inlets and/or outlets.
  - Four-inch discharge opening in riser.
  - Three-inch schedule 40 PVC cast in riser for electrical wiring.
  - Cast-A-Seal and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
  - Pipe materials constructed in conformance with Table SPS 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover, access cover or interior wall.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- All manhole covers terminating above grade must have effective locking devices.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.

January 31, 2012

**Product File No: 20120052**

- Before this product is installed a warning label meeting the requirement of SPS s. 384.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- Tank Bedding: •Bedding should be compacted granular fill that has the ability to pass 100% through as ¾ inch sieve. Bedding should be compacted to a 4 inch minimum depth. In the case of soils with poor bearing capacity, bed design may change to resist floating. Engineering specification may warrant change in bedding specifications.
- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
DSPS WEST, Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@WI.GOV