



March 1, 2012

CRIVITZ REDI-MIX CO.; A DIV. OF MCC, INC.
DAVE URBAN
2600 N ROEMER RD
PO BOX 1137
APPLETON WI 54911

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: CRIVITZ REDI-MIX CO.
Product Name: SEPTIC, HOLDING OR PUMP*
Model Number(s): 1500
(49.5 IN. L.L., 30.5 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 723 G.P.D. WHEN USED AS
A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER; TANK DIMENSIONS (BOTTOM) = 100 IN. L X 73 IN. W X 49.5 IN. H)

Product File No: 20120078

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2017.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - 3/4" diameter opening in the access riser.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- **BEDDING AND BACKFILL: Tank bedding must be 3 in. of compacted sand, gravel or lime rock of which 100% will pass through 1/2-inch screen. Backfill material must be material that 100% will pass through a 4-inch screen and tamped into place.**

This letter is to inform you that on MARCH 1, 2009 revised chapters SPS 382 and 384 (COMM 82 AND 84) of the Wisconsin Administrative Code went into effect. The revisions include the deletion of the requirement for plumbing product approval for EXTERIOR GREASE INTERCEPTORS, s. SPS 384.10. REVIEW OF EXTERIOR GREASE INCEPTORS WILL BE CONDUCTED AT THE TIME OF PROJECT-SPECIFIC PLAN REVIEW.

This approval supersedes the approval issued on 11/15/2006 under product file number 20060460.

CRIVITZ REDI-MIX CO.

Page 2

March 1, 2012

Product File No: 20120078

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060460.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV