



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

March 20, 2012

LABOR AND BIRTH TUB COMPANY LLC
CYNTHIA LEAR STOKES
2226 EASTLAKE AVE. #67
SEATTLE WA 98102

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: LABOR AND BIRTH TUB COMPANY LLC
Product Name: LABOR AND BIRTH BATH TUBS
Model Number(s): AE3000M, AE3000S
Product File No: 20120103

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2017.

This approval is contingent upon compliance with the following stipulation(s):

- This product may connect to the fixture supplies serving a lavatory when the water supply system is designed to adequately supply this product and the lavatory with proper pressure and flow in accordance with SPS 382.40(7) of the Wis. Adm. Code.
- When this product discharges waste through indirect waste piping, the waste must discharge to an acceptable receptor in accordance with SPS 382.33 (8) of the Wis. Adm. Code.
- Installation and maintenance of this product must be in accordance with the manufacturer's printed installation and maintenance instructions.
- Plan review for the installation of this product must be obtained from the department in accordance with SPS 382.20 (1) of the Wis. Adm. Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov