



May 17, 2012

RITZ-CRAFT CORP. OF MI, INC.  
FRANK KRUSZKA  
118 DEAL PKWY  
JONESVILLE MI 49250

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: RITZ-CRAFT CORP. OF MI, INC.  
Product Name: MODULAR HOME-DWV AND WATER LINES  
Model Number(s): RANCH OR 2 STORY INSTALLATION OF: KITCHEN SINK WITH OR WITHOUT  
DISHWASHER AND/OR FOOD WASTE GRINDER (KS1, KS2, KS3, KS4); TOILET (T1);  
SINGLE BOWL VANITY OR UTILITY OR BAR SINK (VS1); WASHER BOX (WB1, WB2,  
WB3); AND TUB SHOWER (TS1) SHOWER (TS2) TUB (TS3)  
Product File No: 20120105

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2017.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on Type L copper tubing must not exceed 31.0 wsfu for 1-inch tubing, 16.5 wsfu for 3/4-inch tubing and 6.5 wsfu for 1/2-inch tubing.

This approval supersedes the approval issued on April 20, 2007 under product file number 20070088.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070088.

RITZ-CRAFT CORP  
Page 2  
May 17, 2012  
20120105

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: [jerry.thompson@wi.gov](mailto:jerry.thompson@wi.gov)