



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

April 5, 2012

JFL MARKETING, INC  
FRANK B. LONGENECKER JR.  
5915 S. PENNSYLVANIA AVE.  
CUDAHY WI 53110

CONES UNIVERSAL LIMITED  
ALAN GLAZE  
WHITEHALL ROAD  
UK  
UNITED KINGDOM

Re: Description: FITTINGS, COPPER, CPVC OR PEX  
Manufacturer: CONES UNIVERSAL LIMITED  
Product Name: B PRESS  
Model Number(s): 1/2" THROUGH 2" PRESS FITTINGS ( FULL LIST OF FITTINGS CAN BE FOUND IN ATTACHMENT "A")  
Product File No: 20120125

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The fittings must be labeled with the manufacturer's name or trade mark, size and tubing material for which the fitting is intended to connect together.
- The fittings must be labeled with the manufacturer's name or trade mark, size and tubing material for which the fitting is intended to connect together.
- This product may be used to join together copper that complies with ASTM B88, CPVC that complies with ASTM D2846 or CSA B137.6 and PEX that complies with ASTM F876, ASTM F877 or ASTM F1281.
- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov