



April 9, 2012

INFILTRATOR SYSTEMS INC.
GOVERNMENT AFFAIRS DEPARTMENT
4 BUSINESS PARK RD
PO BOX 768
OLD SAYBROOK CT 06475

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: INFILTRATOR SYSTEMS INC.
Product Name: SEPTIC*, PUMP, SIPHON, OR HOLDING
Model Number(s): TW-300
[40.0 IN. L.L.; 48 IN. MAX. DEPTH OF BURY; MAX. CAPACITY 313 GALS; MAX. DWF =
150.5 GPD; FOR TANK CAPACITY IN GALS. PER INCH SEE TABLE 1 ATTACHMENT A]
Product File No: 20120146

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MAY 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- Tank bedding shall consist of native soil (without rocks/protrusions).or a minimum of 4 inches of granular material – pea stone, sand, or gravel. Anchoring required if shallow depth to groundwater may result in 18-inch rise.
- * SEPTIC: this tank may provide supplemental septic-tank capacity for instances such as when additional daily volume is created when an addition onto a residence or other structure where an approved septic tank exists, but additional volume capacity is necessary to meet code.

INFILTRATOR SYSTEMS INC.

Page 2

April 9, 2012

Product File No: 20120146

- Additional information is included as attachment(s) to this letter; see attachment A, B and C.

This approval supersedes the approval issued on 10/13/2011 under product file number 20100213.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20100213.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV