



April 10, 2012

INFILTRATOR SYSTEMS INC.  
GOVERNMENT AFFAIRS DEPARTMENT  
4 BUSINESS PARK RD  
PO BOX 768  
OLD SAYBROOK CT 06475

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS  
Manufacturer: INFILTRATOR SYSTEMS INC.  
**Product Name: EZset by INFILTRATOR-- LIDS AND RISERS**  
Model Number(s):  
20 INCH DIAMETER LID, LID-2000; 24 IN DIA. X 6 IN. HT. ACCESS RISER RIS-2406;  
24 INCH DIAMETER LID, LID-2400; 24 IN DIA. X 12 IN. HT. ACCESS RISER RIS-2412;  
30 INCH DIAMETER LID, LID-3000; 24 IN DIA. X 18 IN. HT. ACCESS RISER RIS-2418;  
20 IN DIA. X 6 IN. HT. ACCESS RISER RIS-2006; 30 IN DIA. X 12 IN. HT. ACCESS RISER RIS-3012  
20 IN DIA. X 12 IN. HT. ACCESS RISER RIS-2012;

**Product File No: 20120151**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MAY 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- All manhole covers terminating above grade must have effective locking devices.
- The manhole cover must be secured to the riser using screws which are not standard or phillips head to be considered an effective locking device.
- The joint between the adapter ring shall be secured to the tank cover with a minimum of six screws and sealed with oxime silicone caulk or butyl mastic sealant.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- DESCRIPTION: Stackable risers and lids in 20", 24", and 30" diameters and a variety of heights with slip-resistant, lockable lids to accommodate any new or retrofit installation.
- See also additional information included as attachment(s) to this letter.

This approval supersedes the approval issued on 6/12/2008 under product file number 20080292. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20080292.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
DSPS WEST, Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@WI.GOV