



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

June 13, 2012

LIBERTY PUMPS, INC
JEFFREY WATERMAN
7000 APPLE TREE AVE.
BERGEN NY 14416

Re: Description: MACERATING PUMP SYSTEM
Manufacturer: LIBERTY PUMPS, INC
Product Name: MACERATING TOILET SYSTEM
Model Number(s): ASCENT II - MUW, ASCENT II - ESW, ASCENT II - RSW
Product File No: 20120231

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.30 (10) (b) 3. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The venting system of the connecting fixtures must conform to requirements of SPS 382.31 of the Wisconsin Administrative code
- The discharge pipe must connect to a sanitary drain system in accordance with SPS 382.30 (10) of the Wisconsin Administrative code.
- The venting system serving the macerating unit must conform to requirements of SPS 382.31 of the Wisconsin Administrative code, "vents for sumps".
- This product may serve a toilet, lavatory, shower and/or a bathtub with or without a shower.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov