



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 9, 2012

STICKLER & ASSOCIATES
STEVE STICKLER
203 S. CURNS RD
MILWAUKEE WI 53214

CHARLOTTE PIPE & FOUNDRY
PAUL RIENINGER
2109 RANDOLF RD
CHARLOTTE NC 28207

Re: Description: PIPES AND FITTINGS, CPVC
Manufacturer: CHARLOTTE PIPE & FOUNDRY
Product Name: CHEMDRAIN
Model Number(s): 1 1/2" THROUGH 6" PIPE AND FITTINGS
Product File No: 20120290

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (2) & (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Sanitary drain and vent piping . . gravity flow, above ground or underground
 - b. Sanitary sewer gravity flow
 - c. Storm drain and vent piping . . . gravity flow, above ground or underground
 - d. Storm sewer gravity flow
- This product must be installed and joints made in accordance with the manufacturer's published instructions (i.e. ChemDrain TECHNICAL AND INSTALLATION MANUAL, TM-CD, August 2011).
- All piping system components shall be certified by NSF International for use in chemical waste drain systems and bear the mark NSF-cw.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov