



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 9, 2012

MBA CORPORATION
JOHN ACKERMAN
4388 S. KANAS AVE.
MILWAUKEE WI 53235

IPS CORPORATION
TREY BRADY
500 DISTRIBUTION PKWY
COLLIERVILLE TN 38028

Re: Description: SOLVENT CEMENT
Manufacturer: IPS CORPORATION
Product Name: WELD-ON (IPS) SOLVENTS (SINGLE STEP)
Model Number(s): 704, 705, 721, 725, 727, 735, 737 & 747
Product File No: 20120292

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.40 (14) (b) 1. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be used on PVC gravity flow DWV pipe without primer.
- This product, when used without primer, shall be in accordance to manufactures instructions for "SOLVENT WELDING WITHOUT PRIMER".

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov