



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 10, 2012

DSPS
SAFETY AND BUILDINGS
JERRY THOMPSON
201 W WASHINGTON AVE 4 FL
PO BOX 7162
MADISON WI 53707-7162

Re: Description: CHEMICAL DISPENSING SYSTEM, ALTERNATE FORM OF BACKFLOW PROTECTION
Manufacturer: DEPARTMENT OF COMMERCE
Product Name: CHEMICAL DISPENSING SYSTEM PROTECTION DEVICE
Model Number(s): NONE
Product File No: 20120298

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 (3)(a) and 384.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Chemical dispensing systems that are not in compliant with ASSE Standard 1055, may be installed when the installation includes an acceptable cross connection method or assembly in accordance with SPS 382.41 (3) Table 382.41-1 of the Wisconsin Administrative Code.
- The installation of the cross connection method or assembly must comply with s. SPS 382.41 (5) of the Wisconsin Administrative Code.

This approval supersedes the approval issued on May 25, 2007 under product file number 20070254.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070254.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

James H. Miller
Section Chief, Bureau of Integrated Services
Phone: 608-266-8072
Fax: 608-267-9566
email: jim.miller@wi.gov