



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 23, 2012

SFA SANIFLO INC.
JOSE C. PACHAS
105 NEWFIELD AVE SUITE B
EDISON NJ 08837

Re: Description: MACERATING PUMP SYSTEM
Manufacturer: SFA SANIFLO INC.
Product Name: SANIGRIND MACERATING PUMP SYSTEMS
Model Number(s): SANIBEST PRO (013), SANIGRIND PRO (014)
Product File No: 20120316

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.30 (10) (b) 3.a. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The venting system of the connecting fixtures must conform to requirements of SPS 382.31 of the Wisconsin Administrative code
- The water closet that discharges to the SANIFLO macerating sewage pump system must not discharge more than 1.6 gallons per flush.
- The discharge pipe must connect to a sanitary drain system in accordance with SPS 382.30 (10) of the Wisconsin Administrative code.
- The venting system serving the macerating unit must conform to requirements of SPS 382.31 of the Wisconsin Administrative code, "vents for sumps".

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov