



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

January 3, 2013

MANUFACTURED HOUSING ENTERPRISES
JOHN H. BAILEY
09302 STATE ROUTE 6
BRYAN OH 43506

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: MANUFACTURED HOUSING ENTERPRISES
Product Name: THE PRESTWICK
Model Number(s): 44B04
Product File No: 20120337

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of January 2018.**

This approval is contingent upon compliance with the following stipulation(s):

- This approval is contingent upon compliance with the following stipulation(s):
 1. The flowing water supply pressure at the point(s) of connection must be at least 30.22 psig.
 2. The manufacture must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
 3. This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
 4. Correct the identification letters of sizing for water distribution piping per plan.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone; 608-266-2602 Fax
tim.lamb@wi.gov E-mail

SBD-10564-E (N.10/97)

File Ref: 12033702.DOC