



December 11, 2012

MARK LINE INDUSTRIES INC
DONALD A PAULUS
51687 CR 133
BRISTOL IN 46507-0277

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: MARK LINE INDUSTRIES INC
Product Name: MODULAR BUILDING-DWV AND WATER LINES
Model Number(s): 2460-SAT
Product File No: 20120372

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2017.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be per manufactures calculations at least 58 psig.
- The flowing water supply pressure at the point(s) of connection must be at least 29 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

Please provide a complete set of fresh plumbing system isometric drawings.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

MARK LINE INDUSTRIES INC

Page 2

December 11, 2012

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-266-2602 Fax
tim.lamb@wi.gov E-mail