



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

December 17, 2012

MASCO CORPORATION  
DELTA FAUCET  
MICHAEL MARTINEZ  
55 E 111TH ST.  
INDIANAPOLIS IN 46280

Re: Description: ALTERNATE PRODUCT REVIEW FEE  
Manufacturer: MASCO CORPORATION  
Product Name: CORRENTE  
Model Number(s): C43904-WH  
Product File No: 20120374

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.40 (7) g 382.40 (7) h and 384.20 (6) c , Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2017.

- This alternate approval is required because the fixture supply connector for this fixture, which is integral to this fixture, does not meet the general code requirements for length, dimension and temperature/pressure rating. The integral fixture supply connector may only be used to install this fixture. This fixture may be installed on cold water supplies only.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail