



January 16, 2013

REVISED COPY

INVACARE CORP.
BRIAN SCHAFF
ONE INVACARE WAY
ELYRIA OH 44036

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: INVACARE CORP.
Product Name: RECESSED ACCESS BATH TUB
Model Number(s): 3602G, 3602GXL, 3652G, 3752G AND 3802G
Product File No: 20120391

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2018.

This approval supersedes the approval issued on November 4, 2008 under product file number 20080505.

This approval is contingent upon compliance with the following stipulation(s):

- The 3652G model must be installed with external cross connection control suitable for high hazard [e.g. an air gap (ASME A112.1.2), reduced pressure principle backflow preventer (ASSE 1013)].

The reason for this external cross connection control requirement is the fill valve is located below the flood level rim of the tub.

- This product must discharge its waste to an acceptable receptor in accordance with s. SPS 382.33 (8) of the Wis. Adm. Code.
- This product shall be supplied from the manufacturer with vacuum breakers that conform to ASSE 1011 or 1014 installed in the products water piping. One of them located between the mixing valve and the hand held shower and the other located between the mixing valve and the disinfectant injector (vacuum venturi).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail