



February 14, 2013

H2O CHLORINATION INC.
DOUGLAS HOFFMAN
3643 450TH AVENUE
PO BOX 78
EMMETSBURG IA 50536

Re: Description: WATER TREATMENT CHEMICAL INJECTION DEVICE - POE
Manufacturer: H2O CHLORINATION INC.
Product Name: LAND-O-MATIC
Model Number(s): LP-3000
Product File No: 20120403

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2018.

This approval supersedes the approval issued on June 26, 2009 under product file number 20090200.

This approval is contingent upon compliance with the following stipulation(s):

- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These products have undergone sufficient testing to document their ability to properly inject a chemical into a water supply system as specified in this approval letter.
- Only dry chlorine pellets, Environmental Protection Agency Registration number 89195-1, weighing 1.0 gram, 3/8-inches in diameter, may be used with this product.

The Land-O-Matic calcium hypochlorite pellets are listed under ANSI/NSF Standard 60 and their maximum use concentration is 14.0 mg/l. However, the USEPA has established a maximum residual disinfectant level goal (MRDLG)/maximum residual disinfectant level (MRDL) of 4.0 mg/l for the purpose of minimizing the formation of disinfection byproducts (DBP's). Therefore the free chlorine residual in potable water via the use of these devices shall not exceed 4.0 mg/l.

- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product to inject a chemical into a water supply system. For more information contact the DNR Private Water Systems Section, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- Review the following Wisconsin Department of Natural Resources publications prior to installing, using or otherwise chlorinating a well within the Arsenic Advisory Area:

<http://dnr.wi.gov/topic/Groundwater/images/arsenic/AAA.jpg>

<http://dnr.wi.gov/files/PDF/pubs/DG/DG0069.pdf>

H2O Chlorination Incorporated
February 14, 2013
Page 2 of 2
Product File No.: 20120403

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail