



March 12, 2013

LEDGEVIEW PRECAST CONCRETE, INC.  
ALLEN E. FREUND  
N6672 COUNTY TRUNK UU  
FOND DU LAC WI 54937

Re: Description: SEWAGE TREATMENT APPARATUS (see SEWAGE TANKS, STA-TIERS, ETC.)  
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.  
Product Name: SEDIMENTATION/PUMP, SEPTIC/PUMP, HOLDING OR PUMP  
Model Number(s): 760/1125  
(47.5" L.L., 16.2/26.9 GAL/IN. 48" MAX. DEPTH OF BURY 369 G.P.D. WHEN  
USED AS A SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR  
RESIDENTIAL WASTEWATER)  
Product File No: 20130005

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2018.

This approval supersedes the approval issued on January 9, 2008 under product file number 20080012.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Two inch PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" .
  - Dual inlets at end of tank with an access opening above one inlet and an observation opening over the other inlet.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

Ledgeview Precast Concrete Incorporated  
March 12, 2013  
Page 2 of 2  
Product File No.: 20130005

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail