



March 11, 2013

AL'S CONCRETE PRODUCTS, INC.
BRUCE WIESER
800 TOWNHALL ROAD
LA CRESCENT MN 55947

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: AL'S CONCRETE PRODUCTS, INC.
Product Name: SEPTIC, HOLDING, PUMP, GREASE INTERCEPTOR, SIPHON
Model Number(s): 2250
(47.0" L.L., 27.3 / 49.4 GAL/IN. FOR PUMP CHAMBER, 96" MAX. DEPTH OF BURY, 1111 G.P.D. WHEN USED AS A SEPTIC TANK OR 1158 G.P.D. WHEN USED AS A HOLDING TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20130014

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2018.

This approval supersedes the approval issued on March 17, 2008 under product file number 20080140.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table SPS 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Four inch discharge opening in riser.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with one access opening above each inlet.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - 20" Riser and Cover (3009 & 3009-RC) and 24" Riser and Cover (3008 & 3008-RC) by Polylok.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail