



Scott Walker, Governor  
Dave Ross, Secretary

March 15, 2013

CONTECH CONSTRUCTION PRODUCTS INC.  
TODD M. RIEBAU  
6441 ENTERPRISE LANE SUITE 116  
MADISON WI 53719

CONTECH CONSTRUCTION PRODUCTS, INC.  
DON COLLING, SUPT.  
2214 W WISCONSIN ST  
PO BOX 236  
PORTAGE WI 53901

Re: Description: PIPES AND FITTINGS, ALUMINIZED STEEL (SEE ALSO STORMWATER DETENTION SYSTEMS)  
Manufacturer: CONTECH CONSTRUCTION PRODUCTS, INC.  
Product Name: CONTECH ULTRA-FLO ALTY2 W/SEAM SEALANT; STORMWATER DETENTION PIPING  
Model Number(s): 1" X 1" X 7-1/2" CORRUGATED PIPE AND H-12 DOUBLE BOLT, BAR AND STRAP WITH A BACK UP PLATE AND PROFILE GASKET HUGGER BAND AND O RING GASKETS: 18", 21", 30", 36, 42", 48", 54", 60", 66", 72" AND 78"  
Product File No: 20130022

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (3) (c) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2018.

This approval supersedes the approval issued on May 15, 2008 under product file number 20080265.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must conform to American Association of State Highway and Transportation Officials (AASHTO) standard M36/M 36M-90.
- This product may be installed for the following drain and vent use(s):
  - a. Storm sewer . . . . . gravity flow
- The review undertaken by department staff does not include review and/or approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product is approved for the following use:
  - Stormwater and clearwater subsurface detention system.
- When this product is installed as a subsurface detention system, the installation must be in accordance with the manufacturer's printed instructions. When there is a conflict between the manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.

Sizing of piping for stormwater and clearwater subsurface detention shall be made using hydraulic calculations as specified in manufacturer's instructions.

Contech Construction Products Incorporated  
March 15, 2013  
Page 2 of 2  
Product File No.: 20130022

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail