



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

March 26, 2013

ADVANCED DRAINAGE SYSTEMS  
NYLOPLAST  
TIM RITCHIE  
3130 VERONA AVENUE  
BUFORD GA 30518

ADVANCED DRAINAGE SYSTEMS INC.  
INSERTA TEE COMPANY  
MIKE KEENE  
PO BOX 714  
CORNELIUS OR 97113

Re: Description: FITTINGS, PVC  
Manufacturer: ADVANCED DRAINAGE SYSTEMS INC.  
Product Name: INSERTA TEE  
Model Number(s): 2" - 30"  
Product File No: 20130052

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) (d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2018.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product shall be installed in accordance to the manufacture's instructions.
- A tee cutting jig/hole saw provided by Insertatee Company shall be used to drill the hole in the mainline pipe.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail