



DIVISION OF INDUSTRY SERVICES  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

April 15, 2013

STRATFORD HOMES LTD.  
PAUL SCHROEPFER

PO BOX 37  
STRATFORD WI 54484

Re: Description:        PREFABRICATED PLUMBING SYSTEM  
  Manufacturer:        STRATFORD HOMES LTD.  
  Product Name:        NONE  
  Model Number(s):    S.H.I.-8-88-A  
  Product File No:     20130077

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2018.

This approval supersedes the approval issued on April 25, 2008 under product file number 20080215.

This approval is contingent upon compliance with the following stipulation(s):

1. The flowing water supply pressure at the point(s) of connection must be at least 12 psig.
2. The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
3. Please send a current set of drawings with a copy of this approval letter.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

STRATFORD HOMES LTD.

Page 2

April 15, 2013

Sincerely,

Timothy J. Lamb  
Plumbing Plan Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
Madison WI 53703-2658  
608-266-9647 Phone  
608-266-2602 Fax  
tim.lamb@wi.gov E-mail