



June 5, 2013

CREST PRECAST, INC.
STEVE MADER
609 KISTLER DR
LA CRESCENT MN 55947-1721

Re: Description: GREASE INTERCEPTOR
Manufacturer: CREST PRECAST, INC.
Product Name: GREASE INTERCEPTOR
Model Number(s): 18000
(95" L.L., 84" MAX. DEPTH OF BURY; TANK DIMENSIONS (OD) = 375 IN. L X 133 IN. W
X 122 IN. H)
Product File No: 20130106

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2018.**

This approval supersedes the approval issued on 7/28/2008 under product file number 20080344.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20080344.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones
Public Swimming Pool Plan / Plumbing Product Reviewer
phone: (608) 267-5265
fax: (608) 266-2602
email: glen.jones@wi.gov