



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

June 19, 2013

CONTECH ENGINEERED SOLUTIONS
TODD M. RIEBAU
6441 ENTERPRISE LANE SUITE 116
MADISON WI 53719

Re: Description: STEEL REINFORCED POLYETHENE PIPE AND FITTINGS
Manufacturer: CONTECH ENGINEERED SOLUTIONS
Product Name: DUROMAXX
Model Number(s): 30, 36, 42, 48, 54, 60, 66, 72, 84, 96, 102, 114 AND 120"
Product File No: 20130144

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (2) (b), 384.30 (2) (c) and 384.30 (3) (c) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2018.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The pipe and fittings shall conform to ASTM F 2562/F 2562M-08.
- These pipes and fittings may be used for non-pressurized:
 1. underground drain and vent;
 2. sanitary building sewer; or
 3. storm building sewer
- These pipes and fittings shall be installed in strict accordance with the manufacturer's published instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail