



Scott Walker, Governor
Dave Ross, Secretary

May 31, 2013

REVISED COPY (2nd)

NU FLOW TECHNOLOGIES 2000 INCORPORATED
DEBORAH READ
1313 BOUDARY ROAD SOUTH
OSHAWA ON L1J-6Z7

NU FLOW AMERICA INCORPORATED
DENNIS W. PERSAUD
7710 KENAMAR COURT
SAN DIEGO CA 92121

Re: Description: PIPE LINER
Manufacturer: NU FLOW AMERICA INCORPORATED
Product Name: LATERAL REPAIR SYSTEM
Model Number(s): CURED IN PLACE LATERAL LINER 2" - 8"
Product File No: 20130162

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2018.

This approval supersedes the approval issued on April 23, 2007 under product file number 20070091.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The 4", 6" and 8" size of is product must be installed in accordance with ASTM standard F 1216 – 93 (i.e. inversion method) or ASTM F 1743 (i.e. pull-in-place method).
- The 2" and 3" size of is product must be installed in accordance with the manufacturer's printed installation instructions.
- Piping using this product is limited to receive the maximum drainage fixture units indicated in the following table.

Maximum Number of Drainage Fixture Units Which may Drain Through Any Portion of a Building Drain, Building Subdrain, Building Sewer or Private Interceptor Sewer

Pipe Diameter	Pitch (inch per foot)			
	1/16	1/8	1/4	1/2
2"	NP	NP	4	6
3"	NP	19	22	26
4"	NP	115	138	160
6"	NP	520	624	742
8"	1048	1198	1437	1722

NP = not permitted

- This product may be installed for the following drain or vent use(s):
 - a. Building Drain gravity flow, underground
 - b. Building subdrain gravity flow, underground
 - c. Sanitary sewer gravity flow
 - d. Private Interceptor Main sewer gravity flow
 - e. Building Drain gravity flow, underground
 - f. Building subdrain gravity flow, underground
 - g. Sanitary sewer gravity flow
 - h. Private Interceptor Main sewer gravity flow
 - i. Storm sewer. gravity flow
- This product must be labeled with NuFlow on the product.
- In accordance with ICC Evaluation Service listing “PMG-1147”, as issued on June 1, 2013, an installations log shall be filled out for each individual lateral, all aspects of the pipe and liner are recorded, including pipe diameter, material, defects, cleaning, line length, resin mix and curing timers, a copy of the installation log along with a DVD having the pre-, post- and final video of the liner will be submitted to all clients.
- All installations shall comply with the manufacturer’s published instructions and ch. SPS 382 Wis. Adm. Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail