



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

July 23, 2013

SPRAY MASTER TECHNOLOGIES
ASSEMBLED PRODUCTS CORP
DAN BROWN
115 E LINDEN ST
ROGERS AR 72756

Re: Description: WASHER, PRESSURE
Manufacturer: SPRAY MASTER TECHNOLOGIES
Product Name: WASHDOWN SYSTEM
Model Number(s): SMT-600-W, SMT-600-WC, SMT-600-R, SMT-600-UTC, SMT-600-PE, SMT-1100-RV,
SMT-2000-W, 2000-WC AND SMT-2000-R (MODEL NUMBERS REPRESENT SERIES
NUMBERS)
Product File No: 20130167

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 (3) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2018.

This approval supersedes the approval issued on February 25, 2008 under product file number 20080125.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product uses one or two anti-siphon fill valves for means of protection of the water supply.

The anti-siphon fill valves shall conform to ASSE standard 1002.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail